



ATLANTIC TESTING LABORATORIES

Canton
6431 U.S. Highway 11
P.O. Box 29
Canton, NY 13617
315-386-4578 (T)
315-386-1012 (F)

January 6, 2011

State University of New York at Potsdam
44 Pierrepont Avenue
Potsdam, New York 13676

Attn: Mr. Larry Leashomb
Plant Utilities Engineer

Re: Directed Bulk Sampling and Analysis
Bookstore Entrance
Barrington Student Union
State University of New York at Potsdam
Potsdam, New York
ATL Report No. CT6050AB-01-01-11

Ladies/Gentlemen:

In accordance with the scope of services, outlined in our contract (ATL No. CT5998-220-12-10), dated December 9, 2010, and State University of New York (SUNY) at Potsdam Purchase Order Number 200971, Atlantic Testing Laboratories, Limited (ATL) performed directed bulk sampling. These services were performed on December 10, 2010. The project consisted of the collection of bulk samples from the Bookstore entrance of Barrington Student Union, situated on the SUNY Potsdam campus located at, 44 Pierrepont Avenue, Potsdam, St. Lawrence County, New York.

Summary of Sampling Activities

Suspect Asbestos-Containing Materials

The suspect asbestos-containing materials (ACM) identified during the visual examination included 3 homogenous building materials, from which a total of 7 bulk samples were collected and subsequently submitted to AmeriSci New York, a New York State Department of Health (NYSDOH) approved laboratory (ELAP No. 11480), for analysis by polarized light microscopy (PLM). The laboratory reports and sample custody documentation are enclosed in Appendix A. Copies of pertinent certifications are enclosed in Appendix B.

The Light Gray Mudded Fittings Thermal System Insulation (TSI) sampled was determined to be ACM.

Non-Asbestos-Containing Materials

The materials determined to be non-ACM, as identified during the bulk sampling and asbestos analysis event described herein, are listed below.

- Gray Gypsum Board and Associated
White Joint Compound (Ceiling)

Albany ♦ Binghamton ♦ Elmira ♦ Plattsburgh ♦ Poughkeepsie ♦ Rochester ♦ Syracuse ♦ Utica ♦ Watertown

Sampling Program Limitations

Samples were collected as directed by Mr. Larry Leashomb, representing SUNY Potsdam. This report shall not be used as asbestos abatement specifications or design documents. The field data and findings presented in this report are based on the observations made by representatives of ATL at the time of the sampling event.

Concealed regulated ACM may exist within the Bookstore that may be encountered during renovation activities. If any suspect ACM is encountered during renovation activities, the activities disturbing the suspect ACM must stop and the material should be sampled and laboratory analyzed in accordance with applicable regulations.


Summary of Findings

The following summary of findings is prepared from ATL's understanding that material-specific sampling and analysis was requested within the specified area of the referenced building.

1. The **Gray Mudded Fitting TSI** material sampled was determined to be **ACM**.
2. The **Gray Gypsum Board** and **Associated White Joint Compound** were determined to be **non-ACM**.

Please contact our office should you have any questions, or if we may be of further assistance.

Sincerely,
ATLANTIC TESTING LABORATORIES, Limited



Derek L. Converse
Environmental Scientist

DLC/TJR/dlc

Enclosures

Cc: Mr. Calvin Smith, Environmental Health and Safety Officer

APPENDIX A

LABORATORY REPORTS AND CUSTODY DOCUMENTATION

**AmeriSci New York**117 EAST 30TH ST.
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-3114

PLM Bulk Asbestos ReportAtlantic Testing Laboratories, Limited
Attn: Torey Russell
P.O. Box 29

Canton, NY 13617**Date Received** 12/10/10 **AmeriSci Job #** 210122229
Date Examined 12/10/10 **P.O. #** COC#08337
ELAP # 11480 **Page** 1 of 2
RE: CT6050; SUNY Potsdam; Barrington Student Union;
Bookstore, (Report Amended 12/15/2010)

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
CT6050AB01A 01	210122229-01 Location: Bookstore Entrance Ceiling / Gray Gypsum Board Assoc. White Joint Compound	No	NAD (by NYS ELAP 198.1) by John P. Koubiadis on 12/10/10
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			
CT6050AB01B 01	210122229-02 Location: Bookstore Entrance Ceiling / Gray Gypsum Board Assoc. White Joint Compound	No	NAD (by NYS ELAP 198.1) by John P. Koubiadis on 12/10/10
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			
CT6050AB02A 02	210122229-03 Location: Bookstore Entrance Ceiling / Gray Gypsum Board	No	NAD (by NYS ELAP 198.1) by John P. Koubiadis on 12/10/10
Analyst Description: Grey, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 40 %, Fibrous glass Trace, Non-fibrous 60 %			
CT6050AB02B 02	210122229-04 Location: Bookstore Entrance Ceiling / Gray Gypsum Board	No	NAD (by NYS ELAP 198.1) by John P. Koubiadis on 12/10/10
Analyst Description: Grey, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 35 %, Fibrous glass Trace, Non-fibrous 65 %			
CT6050AB03A 03	210122229-05 Location: Bookstore Entrance / Gray Mudded Pipe Fitting	No	NAD (by NYS ELAP 198.1) by John P. Koubiadis on 12/10/10
Analyst Description: Grey, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Fibrous glass 15 %, Non-fibrous 85 %			

PLM Bulk Asbestos ReportCT6050; SUNY Potsdam; Barrington Student Union;
Bookstore, (Report Amended 12/15/2010)

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
CT6050AB03B 03	210122229-06 Location: Bookstore Entrance / Gray Mudded Pipe Fitting	No	NAD (by NYS ELAP 198.1) by John P. Koubiadis on 12/10/10
Analyst Description: Grey, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Fibrous glass 15 %, Non-fibrous 85 %			
CT6050AB03C 03	210122229-07 Location: Bookstore Entrance / Gray Mudded Pipe Fitting	Yes	12.1 % (by NYS ELAP 198.1) by John P. Koubiadis on 12/10/10
Analyst Description: OffWhite, Homogeneous, Fibrous, Bulk Material Asbestos Types: Chrysotile 12.1 % Other Material: Fibrous glass 10 %, Non-fibrous 77.9 %			

Reporting Notes:

Analyzed by: John P. Koubiadis

*NAD/NSD =no asbestos detected, NA =not analyzed; NA/PS=not analyzed/positive stop; PLM Bulk Asbestos Analysis by EPA 600/M4-82-020 per 40 CFR 763 (NVLAP Lab Code 200546-0), ELAP PLM Method 198.1 for NY friable samples or 198.6 for NOB samples (NY ELAP Lab ID11480);

Note:PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. NAD or Trace results by PLM are inconclusive, TEM is currently the only method that can be used to determine if this material can be considered or treated as non asbestos-containing in NY State (also see EPA Advisory for floor tile,FR 59,146,38970,8/1/94). National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the lab. This PLM report relates ONLY to the items tested. AIHA Lab # 102843.

Reviewed By:

END OF REPORT

APPENDIX B
CERTIFICATIONS

NEW YORK STATE - DEPARTMENT OF LABOR

DIVISION OF SAFETY AND HEALTH
LICENSE AND CERTIFICATE UNIT
STATE CAMPUS BUILDING 12
ALBANY, NY 12240

ASBESTOS HANDLING LICENSE

Atlantic Testing Laboratories, Limited

P.O. Box 29

Canton, NY 13617

FILE NUMBER: 99-0911

LICENSE NUMBER: 29276

LICENSE CLASS: RESTRICTED

DATE OF ISSUE: 10/04/2010

EXPIRATION DATE: 11/30/2011

Duly Authorized Representative – Marijean B. Remington:

This license has been issued in accordance with applicable provisions of Article 30 of the Labor Law of New York State and of the New York State Codes, Rules and Regulations (12 NYCRR Part 56). It is subject to suspension or revocation for a (1) serious violation of state, federal or local laws with regard to the conduct of an asbestos project, or (2) demonstrated lack of responsibility in the conduct of any job involving asbestos or asbestos material.

This license is valid only for the contractor named above and this license or a photocopy must be prominently displayed at the asbestos project worksite. This license verifies that all persons employed by the licensee on an asbestos project in New York State have been issued an Asbestos Certificate, appropriate for the type of work they perform, by the New York State Department of Labor.

Maureen A. Cox

Maureen A. Cox, Director
FOR THE COMMISSIONER OF LABOR

STATE OF NEW YORK - DEPARTMENT OF LABOR
ASBESTOS CERTIFICATE



DEREK CONVERSE

CLASS (EXPIRES)

Q/A7EC(12/11) D/ASP(12/11)

11/11/11 (12/11)



CERT# 07-01125

DMV# 448681638

MUST BE CARRIED ON ASBESTOS PROJECTS

New York State Department of Health Certificate of Asbestos Safety Training

This form is the official record of successful completion of a New York State accredited asbestos safety training course.

Certificate No. **585268**

I - To be completed by Trainee

Name of Trainee (print) <u>Deak Converse</u>	NYS Depart. of Motor Vehicles ID (DMV ID) ¹ <u>748 681 638</u>	
Signature of Trainee <u>[Signature]</u>	Telephone Number <u>(518) 202 4095</u>	Date of Birth ¹ <u>12/25/1972</u>
Address <u>12 Sisson St Port Jervis NY 13856</u> (Street or PO Box) (City) (State) (Zip Code)		

II - To be completed by Training Sponsor

Provider's Name Environmental Education Associates	Telephone Number <u>716 853-2521</u>
Address 346 Austin Street	Course <u>300 Q Asbestos Awareness</u>
Buffalo, New York 14207	Location <u>Buffalo NY</u>
Zip Code <u>14207</u>	

Course Title: Project Monitor ☐ Initial ☒ Refresher ☐ NYS DOH use only
DOH Equivalency?

Training Language: ☒ English ☐ Other: _____ Exam Grade/Date: 92% / 9-10-11

Dates of Training: From: 9/10/10 To: 9/10/10 Expires: 9/10/11

I certify that the asbestos safety training course given on the above date complied with both 10 NYCRR Part 73 and TSCA Title II, was consistent with the curriculum and instructors approved by the New York State Department of Health, and the trainee receiving this certificate completed the training course and successfully passed the examination.

Training Director: Robert W. Doherty (Print) [Signature] (Signature)