

**AmeriSci New York**117 EAST 30TH ST.
NEW YORK, NY 10013

TEL: (212) 679-8600 • FAX: (212) 679-3114

PLM Bulk Asbestos Report

Ambient Environmental, Inc.
Attn: Joella Viscusi
12 Colvin Avenue
Albany, NY 12206

Date Received 05/22/13
Date Examined 05/22/13
ELAP # 11480

AmeriSci Job # 213054325
P.O. #
Page 1 of 2

RE: 130520AA: SUNY Potsdam; Barrington Student Union - Floor
Tile Disturbance; 44 Pierrepont Ave.; Potsdam, NY; Dining Hall

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
01-01 Location: Outside "West" Entrance / Green Floor Tile	213054325-01	No	NAD (by NYS ELAP 199.6) by Ella Babayeva on 05/22/13
Analyst Description: Green, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 48.4 %			
02-02 Location: 4" West Of Counter / Red Floor Tile	213054325-02	No	NAD (by NYS ELAP 199.6) by Ella Babayeva on 05/22/13
Analyst Description: Red, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 46.8 %			
03-04 03 Location: 4" From North Below "Stage" / "White" 6x9 Floor Tile	213054325-03	No	NAD (by NYS ELAP 199.6) by Ella Babayeva on 05/22/13
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 5.7 %			
03-03 03 Location: Center Below "Stage" / "White" 6x9 Floor Tile	213054325-04	No	NAD (by NYS ELAP 199.6) by Ella Babayeva on 05/22/13
Analyst Description: White, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 7 %			
04-05 04 Location: "West" End Of "Stage" / Yellow (6x9) Tile Adh.	213054325-05	No	NAD (by NYS ELAP 199.6) by Ella Babayeva on 05/22/13
Analyst Description: Yellow, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 28.7 %			

See Reporting notes on last page

AmeriSci Job #: 213054325

Page 2 of 2

Client Name: Ambient Environmental, Inc.

PLM Bulk Asbestos Report

130570AA: SUNY Potsdam; Barrington Student Union - Floor
 Tile Disturbance: 44 Piermont Ave.; Potsdam, NY: Dining Hall

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
04-06 04	213054325-06 Location: 6' From "West" End Of "Blaze" / Yellow (9x9) Tile Adh.	No	NAD (by NYS ELAP 186.6) by Ella Babayeva on 05/22/13
Analyst Description: Yellow, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 30.3 %			
05-07 05	213054325-07 Location: "West" Side Of Counter / Debris	No	NAD ¹ (by NYS ELAP 186.1) by Ella Babayeva on 05/22/13
Analyst Description: White/Brown/Green, Heterogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			
05-08 05	213054325-08 Location: "North" Side Of Counter / Debris	No	NAD ¹ (by NYS ELAP 186.1) by Ella Babayeva on 05/22/13
Analyst Description: White/Red/Brown, Heterogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 100 %			

Reporting Notes:

(1) Analysis Results For Soil, Dust, Or Debris May Be Highly Variable Because Of The Heterogeneous Nature Of These Samples

Analyzed by: Ella Babayeva *Ella Babayeva*
 *NAD/NSD: no asbestos detected; NA: not analyzed; NAFG: not analyzed/positive drop; PLM Bulk Asbestos Analysis by EPA 800/M4-82-020 per 40 CFR 163 (NYS Lab Code 205.941-0), ELAP PLM Method 186.1 for NY friable samples, which includes the identification and quantification of vermiculite or 100.0 for NCB samples (NY ELAP Lab ID 11450). Note: PLM is not consistently reliable in detecting asbestos in floor coverings and similar non friable organically bound materials. NAD or Trace results by PLM are inconclusive; TEM is currently the only method that can be used to determine if this material can be considered or treated as non asbestos-containing in NY State (also see EPA Advisory for floor tile, FR 52,140,06073,6/1/99). National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the lab. This PLM report relates ONLY to the items tested. AHA Lab # 102649, RI Certificate 001, CT Certificate 0128, Mass Certificate 000004

Reviewed by: _____

END OF REPORT

130520AA; SUNY Potsdam; Barrington Students Union - Floor Tilt Disturbance; 41 Pierrepont Ave.; Potsdam, NY Dining Hall

Reviewed by:

