



Please Reply To:

AmeriSci New York

117 EAST 30TH ST.
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-3114

FACSIMILE TELECOPY TRANSMISSION

To: Joe Grabowski
Atlantic Testing Laboratories, Limited
Fax #:
Email: jgrabowski@atlantictesting.com, ameriscict@atlantictesting.com

From: Ivan H. Reyes
AmeriSci Job #: 215093678
Subject: ELAP-PLM/TEM rush Results
Client Project: CT6768; Snell Lobby / Barrington Room; SUNY Potsdam

Date: Wednesday, September 23, 2015
Time: 16:21:57

Number of Pages: 6
(including cover sheet)

Comments:

CONFIDENTIALITY NOTICE: Unless otherwise indicated, the information contained in this communication is confidential information intended for use of the individual named above. If the reader of this communication is not the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is prohibited. If you have received this communication in error, please immediately notify the sender by telephone and return the original message to the above address via the US Postal Service at our expense. Samples are disposed of in 60 days or unless otherwise instructed by the protocol or special instructions in writing. Thank you.

Certified Analysis Service 24 Hours A Day • 7 Days A Week Competitive Prices
visit our web site - www.ameriscisci.com

Boston • Los Angeles • New York • Richmond



AmeriSci New York

117 EAST 30TH ST.
NEW YORK, NY 10016

TEL: (212) 679-8600 • FAX: (212) 679-3114

PLM Bulk Asbestos Report

Atlantic Testing Laboratories, Limited
Attn: Joe Grabowski
P.O. Box 29

Canton, NY 13617

Date Received 09/23/15 **AmeriSci Job #** 215093678
Date Examined 09/23/15 **P.O. #** 17096
ELAP # 11480 **Page** 1 **of** 3
RE: CT6768; Snell Lobby / Barrington Room; SUNY Potsdam

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
CT6768AB01A 01 Location: Snell Lobby - Grey Mudded Fitting	215093678-01	No	NAD (by NYS ELAP 198.1) by Ivan H. Reyes on 09/23/15
Analyst Description: Grey, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose Trace, Fibrous glass 25 %, Non-fibrous 75 %			
CT6768AB01B 01 Location: Snell Lobby - Grey Mudded Fitting	215093678-02	No	NAD (by NYS ELAP 198.1) by Ivan H. Reyes on 09/23/15
Analyst Description: Grey, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose Trace, Fibrous glass 25 %, Non-fibrous 75 %			
CT6768AB01C 01 Location: Snell Lobby - Grey Mudded Fitting	215093678-03	No	NAD (by NYS ELAP 198.1) by Ivan H. Reyes on 09/23/15
Analyst Description: Grey, Homogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose Trace, Fibrous glass 30 %, Non-fibrous 70 %			
CT6768AB02A 02 Location: Snell Lobby - Tan TSI Paper Jacket	215093678-04	No	NAD (by NYS ELAP 198.1) by Ivan H. Reyes on 09/23/15
Analyst Description: OffWhite/Silver, Heterogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 75 %, Fibrous glass 3 %, Non-fibrous 22 %			
CT6768AB02B 02 Location: Snell Lobby - Tan TSI Paper Jacket	215093678-05	No	NAD (by NYS ELAP 198.1) by Ivan H. Reyes on 09/23/15
Analyst Description: OffWhite/Silver, Heterogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 70 %, Fibrous glass 3 %, Non-fibrous 27 %			

PLM Bulk Asbestos Report


CT6768; Snell Lobby / Barrington Room; SUNY Potsdam

Client No. / HGA	Lab No.	Asbestos Present	Total % Asbestos
CT6768AB02C 02	215093678-06 Location: Snell Lobby - Tan TSI Paper Jacket	No	NAD (by NYS ELAP 198.1) by Ivan H. Reyes on 09/23/15
Analyst Description: OffWhite/Silver, Heterogeneous, Fibrous, Bulk Material Asbestos Types: Other Material: Cellulose 70 %, Fibrous glass 3 %, Non-fibrous 27 %			
CT6768AB03A 03	215093678-07 Location: Barrington Room - Light Green Cove Base	No	NAD (by NYS ELAP 198.6) by Ivan H. Reyes on 09/23/15
Analyst Description: Light Green, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 41 %			
CT6768AB03B 03	215093678-08 Location: Barrington Room - Light Green Cove Base	No	NAD (by NYS ELAP 198.6) by Ivan H. Reyes on 09/23/15
Analyst Description: Light Green, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 41.4 %			
CT6768AB04A 04	215093678-09 Location: Barrington Room - Yellow Cove Base Adhesive	No	NAD (by NYS ELAP 198.6) by Ivan H. Reyes on 09/23/15
Analyst Description: Yellow, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 31.4 %			
CT6768AB04B 04	215093678-10 Location: Barrington Room - Yellow Cove Base Adhesive	No	NAD (by NYS ELAP 198.6) by Ivan H. Reyes on 09/23/15
Analyst Description: Yellow, Homogeneous, Non-Fibrous, Bulk Material Asbestos Types: Other Material: Non-fibrous 25.4 %			

PLM Bulk Asbestos Report

CT6768; Snell Lobby / Barrington Room; SUNY Potsdam

Reporting Notes:

Analyzed by: Ivan H. Reyes 

*NAD/NSD =no asbestos detected; NA =not analyzed; NA/PS=not analyzed/positive stop; PLM Bulk Asbestos Analysis by EPA 600/M4-82-020 per 40 CFR 763 (NVLAP 200546-0), ELAP PLM Method 198.1 for NY friable samples, which includes the identification and quantitation of vermiculite or 198.6 for NOB samples or EPA 400 pt ct by EPA 600/M4-82-020 (NY ELAP Lab 11480); Note:PLM is not consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials. NAD or Trace results by PLM are inconclusive, TEM is currently the only method that can be used to determine if this material can be considered or treated as non asbestos-containing in NY State (also see EPA Advisory for floor tile, FR 59,146,38970,8/1/94) National Institute of Standards and Technology Accreditation requirements mandate that this report must not be reproduced except in full without the approval of the lab.This PLM report relates ONLY to the items tested. AIHA-LAP, LLC Lab ID 102843, RI Cert AAL-094, CT Cert PH-0186, Mass Cert AA000054.

Reviewed By: _____ END OF REPORT _____

Table I
Summary of Bulk Asbestos Analysis Results
 CT6768; Snell Lobby / Barrington Room; SUNY Potsdam

AmeriSci Sample #	Client Sample#	HG Area	Sample Weight (gram)	Heat Sensitive Organic %	Acid Soluble Inorganic %	Insoluble Non-Asbestos Inorganic %	** Asbestos % by PLM/DS	** Asbestos % by TEM
01	CT6768AB01A	01	---	---	---	---	NAD	NA
Location:	Snell Lobby - Grey Muddled Fitting							
02	CT6768AB01B	01	---	---	---	---	NAD	NA
Location:	Snell Lobby - Grey Muddled Fitting							
03	CT6768AB01C	01	---	---	---	---	NAD	NA
Location:	Snell Lobby - Grey Muddled Fitting							
04	CT6768AB02A	02	---	---	---	---	NAD	NA
Location:	Snell Lobby - Tan TSI Paper Jacket							
05	CT6768AB02B	02	---	---	---	---	NAD	NA
Location:	Snell Lobby - Tan TSI Paper Jacket							
06	CT6768AB02C	02	---	---	---	---	NAD	NA
Location:	Snell Lobby - Tan TSI Paper Jacket							
07	CT6768AB03A	03	0.251	28.7	30.3	41.0	NAD	NAD
Location:	Barrington Room - Light Green Cove Base							
08	CT6768AB03B	03	0.220	30.0	28.6	41.4	NAD	NAD
Location:	Barrington Room - Light Green Cove Base							
09	CT6768AB04A	04	0.245	63.3	5.3	31.4	NAD	NAD
Location:	Barrington Room - Yellow Cove Base Adhesive							
10	CT6768AB04B	04	0.224	67.9	6.7	25.4	NAD	NAD
Location:	Barrington Room - Yellow Cove Base Adhesive							

Analyzed by: Aleksandr Barengolts; Date Analyzed 9/23/2015

**Quantitative Analysis (Semi/Full): Bulk Asbestos Analysis - PLM by EPA 600/M4-82-020 per 40 CFR or ELAP 198.1 for New York friable samples or ELAP 198.6 for New York NOB samples; TEM (Semi/Full) by EPA 600/R-93/116 (not covered by NVLAP Bulk accreditation) or ELAP 198.4; for New York samples; NAD = no asbestos detected during a quantitative analysis; NA = not analyzed; Trace = <1%; Quantitation for beginning weights of <0.1 grams should be considered as qualitative only; Qualitative Analysis: Asbestos analysis results of "Present" or "NVA = No Visible Asbestos" represents results for Qualitative PLM or TEM Analysis only (no accreditation coverage available from any regulatory agency for qualitative analyses); NVLAP 200546-0, NYSDOH ELAP Lab 11480, AIHA Lab 102843.

Warning Note: PLM limitation, only TEM will resolve fibers <0.25 micrometers in diameter. TEM bulk analysis is representative of the fine grained matrix material and may not be representative of non-uniformly dispersed debris for which PLM evaluation is recommended (i.e. soils and other heterogeneous materials).

Reviewed By: _____



ATLANTIC TESTING LABORATORIES

ASBESTOS BULK SAMPLE CHAIN-OF-CUSTODY RECORD

17096

Albany
22 Corporate Drive
Clifton Park, NY 12065
518/383-9144 (T)
518/383-9166 (F)

Binghamton
126 Park Avenue
Binghamton, NY 13903
607/773-1812 (T)
607/773-1835 (F)

Canton
6947 U.S. Highway 11
Canton, NY 13617
315/386-4578 (T)
315/386-1012 (F)

Elmira
2330 Route 352
Elmira, NY 14903
607/737-0700 (T)
607/737-0714 (F)

Plattsburgh
130 Arizona Ave
Plattsburgh, NY 12903
518/563-5878 (T)
518/562-1321 (F)

Poughkeepsie
251 Upper North Road
Highland, NY 12528
845/691-6098 (T)
845/691-6099 (F)

Rochester
3495 Winton Place
Rochester, NY 14623
585/427-9020 (T)
585/427-9021 (F)

Syracuse
6085 Court Street Road
Syracuse, NY 13206
315/699-5281 (T)
315/699-3374 (F)

Utica
301 St. Anthony Street
Utica, NY 13501
315/735-3309 (T)
315/735-0742 (F)

Watertown
26581 NYS Route 283
Watertown, NY 13601
315/786-7887 (T)
315/786-2022 (F)

Project No.	Project Name	Date Collected	Laboratory Instructions	Report Distribution
CT6768	Snell Lobby 1	9/29/15	Turn-Around Time: ☐ 12hr ☐ 24hr ☐ 48hr ☐ 72hr ☐ 5day ☒ RUSH 4 hr. ☒	Send Reports To (ATL Office): ATL Contact: Send Copy To: Email Results: ☒ YES ☐ NO
Project Contact:	Joe Grubowski		Special Instructions: ☒ Positive Stop Analysis ☒ If negative by PLM-NOB, analyze by TEM-NOB ☐ Other	Carsten Office jgrubowski@atl.com
Project Location:	Sunny Potsdam			
Field Sample No.	Sample Location	Sample Description	Analysis Requested	Laboratory Sample ID No.
AB01A	Snell Lobby	Grey Muddled Fitting	PLM ☒ TEM-NOB ☒ MICRO -VAC ☒	
AB01B	Snell Lobby	Grey Muddled Fitting	PLM ☒ TEM-NOB ☒ MICRO -VAC ☒	
AB01C	Snell Lobby	Grey Muddled Fitting	PLM ☒ TEM-NOB ☒ MICRO -VAC ☒	
AB02A	Snell Lobby	Tan 11 Paper Jacket	PLM ☒ TEM-NOB ☒ MICRO -VAC ☒	
AB02B	Snell Lobby	Tan 11 Paper Jacket	PLM ☒ TEM-NOB ☒ MICRO -VAC ☒	
AB02C	Snell Lobby	Tan 11 Paper Jacket	PLM ☒ TEM-NOB ☒ MICRO -VAC ☒	
AB03A	Barrington Room	Light Green Corbuse	PLM ☒ TEM-NOB ☒ MICRO -VAC ☒	
AB03B	Barrington Room	Light Green Corbuse	PLM ☒ TEM-NOB ☒ MICRO -VAC ☒	
AB04A	Barrington Room	Yellow Corbuse Adhesive	PLM ☒ TEM-NOB ☒ MICRO -VAC ☒	
AB04B	Barrington Room	Yellow Corbuse Adhesive	PLM ☒ TEM-NOB ☒ MICRO -VAC ☒	
			#215093678	
Sampler's Name:	Timothy Parker	Date: 9/29/15	Received at Laboratory (Name):	Shipment Rec'd Intact
Sampler's Signature:	[Signature]	Time: 14:00	Laboratory Signature:	☐ YES ☐ NO
Name:	Timothy Parker	Date: 9/29/15	Samples Received By:	Field and Laboratory Remarks:
Signature:	[Signature]	Time: 18:00	Name: [Signature]	
Name:		Date:	Name:	
Signature:		Time:	Signature:	

Think Quality

Distribution: White with Samples
Yellow to Laboratory
Pink to ATL Files