



Tim 052109A-ENV-AIR MON

Asbestos Air Sampling Analysis Report

Analyzed in accordance with
NIOSH Method 7400 (A Rules)
NYS DOH ELAP #11555

Client: SUNY College at Potsdam - 44 Pierre Pont Ave., Potsdam, NY 13676

Project Location: Timerman - 2nd Project - Floor Tile/Mastic

Project Number: EL09A-7

Client Contact: Andy Martin

Phone Number: (315) 267-2135

Contractor: Op-Tech

Report Number: 1233

Date Sampled: 5-21-09

Date Received: 5-24-09

Date Analyzed: 5-24-09

Date Reported: 5-26-09

Summary: On May 21, 2008, our representative, Scott Landry, collected the following samples in accordance with all state and federal regulations.

Work Area Location	Sample Type	Elapsed Time Minutes	Flow Rate L/Min	Volume liters	Result f/mm ²	Result f/cc	Field ID	Lab ID
Inside Work Area - East	B	90	10.0	900	<6.87	<0.003	13	7940
Inside Work Area - West	B	90	10.0	900	<6.87	<0.003	14	7941
Inside Work Area - Center	B	90	10.0	900	<6.87	<0.003	15	7942
Inside Work Area - North	B	90	10.0	900	<6.87	<0.003	16	7943
Inside Work Area - South	B	90	10.0	900	<6.87	<0.003	17	7944
Outside Work Area - Staircase	B	90	10.0	900	<6.87	<0.003	18	7945
Outside Work Area - Staircase	B	90	10.0	900	<6.87	<0.003	19	7946
Outside Work Area - Staircase	B	90	10.0	900	<6.87	<0.003	20	7947
Outside Work Area - Staircase	B	90	10.0	900	<6.87	<0.003	21	7948
Outside Work Area - Staircase	B	90	10.0	900	<6.87	<0.003	22	7949
Field Blank	FB	NA	NA	NA	NC	NC	23	7950
Field Blank	FB	NA	NA	NA	NC	NC	24	7951

High or unusual results are highlighted and italicized.

ABBREVIATIONS:

B = Background Sample

PA = Pre - Abatement Sample

E = Daily Environmental Sample

F = Final Clearance Sample

WA = Work Area Sample

STEL/EL = Short Term Exposure/Excursion Limit Sample

P = OSHA Personal Air Monitoring Sample

FB = Field Blank

NC = Non-Contaminated

MD = Mineral Dust, Unable to Analyze

SD = Sample Damaged, Unable to Analyze

f/cc = Fibers Per Cubic Centimeter

f/mm² = Fibers Per Square Millimeter

< = Below Detection Limit

NS = Not Supplied

NA = Not Applicable

Valerie Lare

Approved By: Valerie Lare

Technical Director - Envirologic of New York, Inc.

Disclaimer: NIOSH Method 7400 is a method used for estimating asbestos concentrations, however, phase contrast microscopy cannot distinguish between asbestos fibers and other fiber types. The analytical results presented in this report and the laboratory procedures used are considered to be accurate and reliable for the samples analyzed. This report may not be reproduced without the approval of Envirologic New York, Inc., and then only in full. Envirologic of New York's liability is limited to the cost of the analysis.

Envirologic of New York, Inc.

Central Office: 6950 East Genesee Street, Fayetteville, New York 13066

Ph: (315) 455-2714 Fax: (315) 455-3022



Air Sample Log / Chain of Custody

6950 E. Genesee St. • Fayetteville, New York 13066 • Telephone (315) 455-2714 • Fax (315) 455-3022

PROJECT #: EL09A-7

LAB REPORT #: 1233

Project Name/City/Project Info:		Client Name:	Client phone #:
Five-Point Hill		Sony Potsdam	
2nd Project		Client Address:	Client fax #:
Floor Tyle		44 Percepsant Ave. Potsdam, NY	
Date: 5-21-09		Hygienist:	Calibration: 4/14-09
Contractor: Op-Tech		Contact: Andy Madia	Rotometer #: E22

Sample Number	Lab ID	Work Area ID	Sample Location	Sample Type	Pump #	Start Time	Stop Time	Total Minutes	Calibration		Volume (Liters)
									l/m	l/m	
13	7940		I.W.A EAST	B	8	08:45	10:15	90	10	10	900
14	7941		WEST		5	08:46	10:16		10	10	
15	7942		Center		024	08:47	10:17		10	10	
16	7943		NORTH		22	08:48	10:18		10	10	
17	7944		SOUTH		009	08:49	10:19		10	10	
18	7945		O.W.A		078	08:55	10:25		10	10	
19	7946		All pumps are in front		3	08:56	10:26		10	10	
20	7947		1st staircase across		36	08:57	10:27		10	10	
21	7948		From work		6	08:58	10:28		10	10	
22	7949		Area		630	08:59	10:29		10	10	
23	7950		Field Blank	FB							
24	7951		Field Blank	FB							

Sample Type: B = Background PA = Pre-Abatement E = Environmental WA = Work Area F = Final BL = Blank P = Personal EL = Excursion Limit

Chain of Custody	Print Name	Sign Name	Date	Time
Sampled By:	Scott Landry		5-21-09	
Relinquished By:	Scott Landry		5-21-09	
Received at Lab By:	Carlisle Rendell		5/24/09	
Turnaround Time:	RUSH (Specify):		24 Hour	48 Hour
Please contact the following individual(s) at the following number(s) with results:				
24 Hour 72 Hour Other:				

By signing above, I acknowledge that the data recorded on this form was collected by accurately following air-sampling procedures outlined in NYSDOL Industrial Code Rule 56 (12 NYCRR Part 56, Subpart 56-4, 56-6, 56-7.1, 56-8.1, 56-9.1, 56-10.1) and all other applicable state and federal regulations.