



Asbestos Air Sampling Analysis Report

Analyzed in accordance with
NIOSH Method 7400 (A Rules)
NYS DOH ELAP #11555

Client: SUNY College at Potsdam - 44 Pierre Pont Ave., Potsdam, NY 13676
Project Location: Timmerman Basement - 1st Project - Floor Tile/Mastic
Project Number: EL09A-7
Client Contact: Andy Martin
Phone Number: (315) 267-2135

Contractor: Op-Tech

Report Number: 1232
Date Sampled: 5-21-09
Date Received: 5-24-09
Date Analyzed: 5-26-09
Date Reported: 5-26-09

Summary: On May 21, 2008, our representative, Scott Landry, collected the following samples in accordance with all state and federal regulations.

Work Area Location	Sample Type	Elapsed Time Minutes	Flow Rate L/Min	Volume liters	Result f/mm ²	Result f/cc	Field ID	Lab ID
Inside Work Area - East	B	90	10.0	900	16.23	0.007	1	7928
Inside Work Area - West	B	90	10.0	900	13.73	0.006	2	7929
Inside Work Area - Center	B	90	10.0	900	9.99	0.004	3	7930
Inside Work Area - North	B	90	10.0	900	8.74	0.004	4	7931
Inside Work Area - South	B	90	10.0	900	<6.87	<0.003	5	7932
Outside Work Area - Bottom of Stairs	B	90	10.0	900	14.98	0.006	6	7933
Outside Work Area - Bottom of Stairs	B	90	10.0	900	8.74	0.004	7	7934
Outside Work Area - Bottom of Stairs	B	90	10.0	900	7.49	0.003	8	7935
Outside Work Area - Bottom of Stairs	B	90	10.0	900	<6.87	<0.003	9	7936
Outside Work Area - Bottom of Stairs	B	90	10.0	900	<6.87	<0.003	10	7937
Field Blank	FB	NA	NA	NA	NC	NC	11	7938
Field Blank	FB	NA	NA	NA	NC	NC	12	7939

High or unusual results are highlighted and italicized.

ABBREVIATIONS:

B = Background Sample

PA = Pre - Abatement Sample

E = Daily Environmental Sample

F = Final Clearance Sample

WA = Work Area Sample

STEL/EL = Short Term Exposure/Excursion Limit Sample

P = OSHA Personal Air Monitoring Sample

FB = Field Blank

NC = Non-Contaminated

MD = Mineral Dust, Unable to Analyze

SD = Sample Damaged, Unable to Analyze

f/cc = Fibers Per Cubic Centimeter

f/mm² = Fibers Per Square Millimeter

< = Below Detection Limit

NS = Not Supplied

NA = Not Applicable

Valerie Lare

Approved By: Valerie Lare
Technical Director - Envirologic of New York, Inc.

Disclaimer: NIOSH Method 7400 is a method used for estimating asbestos concentrations, however, phase contrast microscopy cannot distinguish between asbestos fibers and other fiber types. The analyt results presented in this report and the laboratory procedures used are considered to be accurate and reliable for the samples analyzed. This report may not be reproduced without the approval of Envirologic New York, Inc., and then only in full. Envirologic of New York's liability is limited to the cost of the analysis.

Envirologic of New York, Inc.

Central Office: 6950 East Genesee Street, Fayetteville, New York 13066

Ph: (315) 455-2714 Fax: (315) 455-3022



Air Sample Log / Chain of Custody

6950 E. Genesee St. • Fayetteville, New York 13066 • Telephone (315) 455-2714 • Fax (315) 455-3022

PROJECT #: EL09A-7

LAB REPORT #: 1232

Project Name/City/Project Info: 1st Project FLOETILE Timmerman Basement W-MASTIC		Client Name: Sony Polsdam		Client phone #:
Date: 5-21-09		Client Address: 44 Pierrepont Ave. Rosdam NY		Client fax #:
Contractor: Op-Tech		Hygienist:		Calibration: 4-14-09
		Contact: Amy Platta	Rotometer #: E22	

Sample Number	Lab ID	Work Area ID	Sample Location	Sample Type	Pump #	Start Time	Stop Time	Total Minutes	Calibration l/m	Volume (Liters)
1	7928		TWA EAST	B	8	06:45	08:15	90	10	900
2	7929		WEST		009	06:46	08:16		10	
3	7930		Center		024	06:47	08:17		10	
4	7931		NORTH		22	06:48	08:18		10	
5	7932		SOUTH		5	06:49	08:19		10	
6	7933		QWA		316	07:00	08:30		10	
7	7934		All pumps are at		630	07:01	08:31		10	
8	7935		bottom of staircase		6	07:02	08:32		10	
9	7936		outside work Area		3	07:03	08:33		10	
10	7937				078	07:04	08:34		10	
11	7938		Field Blank	FB						
12	7939		Field Blank	FB						

Sample Type: B = Background PA = Pre-Abatement E = Environmental WA = Work Area F = Final BL = Blank P = Personal EL = Excursion Limit

Chain of Custody	Print Name	Sign Name	Date	Time
Sampled By:	Scott Landry	<i>Scott Landry</i>	5-21-09	
Relinquished By:	Scott Landry	<i>Scott Landry</i>	5-21-09	
Received at Lab By:	Carline Rendell	<i>Carline Rendell</i>	5-21-09	
Turnaround Time:	RUSH (Specify):		24 Hour	48 Hour
Please contact the following individual(s) at the following number(s) with results:				

By signing above, I acknowledge that the data recorded on this form was collected by accurately following air-sampling procedures outlined in NYSDOL Industrial Code Rule 56 (12 NYCRR Part 56, Subpart 56-4, 56-6, 56-7.1, 56-8.1, 56-9.1, 56-10.1) and all other applicable state and federal regulations.