



Tim 052209A
Asbestos Air Sampling Analysis Report

Analyzed in accordance with
 NIOSH Method 7400 (A Rules)
 NYS DOH ELAP #11555

Client: SUNY College at Potsdam - 44 Pierre Pont Ave., Potsdam, NY 13676
Project Location: Timerman - Hall (Proj. #1)/Basement (Proj. #2) - Floor Tile/Mastic
Project Number: EL09A-7
Client Contact: Andy Martin
Phone Number: (315) 267-2135

Contractor: Op-Tech

Report Number: 1231
Date Sampled: 5-22-09
Date Received: 5-24-09
Date Analyzed: 5-24-09
Date Reported: 5-26-09

Summary: On May 22, 2008, our representative, Scott Landry, collected the following samples in accordance with all state and federal regulations.

Work Area Location	Sample Type	Elapsed Time Minutes	Flow Rate L/Min	Volume liters	Result f/mm ²	Result f/cc	Field ID	Lab ID
Ambient	E	360	2.0	720	<6.87	<0.004	1	7915
Critical Barrier #2 - Project #1	E	320	2.0	640	<6.87	<0.004	2	7916
Critical Barrier #2 - Project #1	E	320	2.0	640	<6.87	<0.017	3	7917
Critical Barrier #1 - Project #2	E	VOID	VOID	VOID	VOID	VOID	4	7918
Critical Barrier #2 - Project #2	E	VOID	VOID	VOID	VOID	VOID	5	7919
Personal Decon - Project #1	E	315	2.0	630	<6.87	<0.004	6	7920
Personal Decon - Project #2	E	VOID	VOID	VOID	VOID	VOID	7	7921
Waste Out - Project #1	E	325	2.0	650	<6.87	<0.004	8	7922
Waste Out - Project #2	E	VOID	VOID	VOID	VOID	VOID	9	7923
Negative Air - Project #1	E	350	2.0	700	<6.87	<0.004	10	7924
Negative Air - Project #2	E	VOID	VOID	VOID	VOID	VOID	11	7925
Field Blank	FB	NA	NA	NA	NC	NC	12	7926
Field Blank	FB	NA	NA	NA	NC	NC	13	7927

High or unusual results are highlighted and italicized.

ABBREVIATIONS:

B = Background Sample

PA = Pre - Abatement Sample

E = Daily Environmental Sample

F = Final Clearance Sample

WA = Work Area Sample

STEL/EL = Short Term Exposure/Excursion Limit Sample

P = OSHA Personal Air Monitoring Sample

FB = Field Blank

NC = Non-Contaminated

MD = Mineral Dust, Unable to Analyze

SD = Sample Damaged, Unable to Analyze

f/cc = Fibers Per Cubic Centimeter

f/mm² = Fibers Per Square Millimeter

< = Below Detection Limit

NS = Not Supplied

NA = Not Applicable

Valerie Lare

Approved By: Valerie Lare
 Technical Director - Envirologic of New York, Inc.

Disclaimer: NIOSH Method 7400 is a method used for estimating asbestos concentrations, however, phase contrast microscopy cannot distinguish between asbestos fibers and other fiber types. The analyt results presented in this report and the laboratory procedures used are considered to be accurate and reliable for the samples analyzed. This report may not be reproduced without the approval of Envirologic New York, Inc., and then only in full. Envirologic of New York's liability is limited to the cost of the analysis.

Envirologic of New York, Inc.

Central Office: 6950 East Genesee Street, Fayetteville, New York 13066

Ph: (315) 455-2714 Fax: (315) 455-3022



Air Sample Log / Chain of Custody

6950 E. Genesee St. • Fayetteville, New York 13066 • Telephone (315) 455-2714 • Fax (315) 455-3022

PROJECT #: EL09A-7

LAB REPORT #: 1231

Project Name/City/Project Info: Project 1 Project 2 Timesman Hall Basement	Client Name: Sunny Potsdam	Client phone #:
Date: 5-22-09	Client Address: 44 Perrepoint Ave. Potsdam, NY	Client fax #:
Contractor: Op-Tech	Hygienist:	Calibration: 4-14-09
	Contact: Andy Martin	Rotometer #: 622

Sample Number	Lab ID	Work Area ID	Sample Location	Sample Type	Pump #	Start Time	Stop Time	Total Minutes	Calibration	Volume (Liters)
1	7915		Ambient	E	60	07:00	13:00	360	2.0	720
2	7916		Critical - Project 1		61	07:20	12:40	320	2.0	640
3	7917		Critical - Project 1		62	07:21	12:41	320	2.0	640
4	7918		Critical - Project 2		63	NOT	STARTING	Project today		
5	7919		Critical - Project 2		64	07:30	12:45	315	2.0	630
6	7920		Personal Decon - Project 1		65	NOT	STARTING	Project today		
7	7921		Personal Decon - Project 1		66	07:25	12:50	325	2.0	650
8	7922		Waste Out - Project 1		67	NOT	STARTING	PROJECT TODAY		
9	7923		Waste Out - Project 2		68	07:05	12:55	350	2.0	700
10	7924		Neg Air - Project 1			NOT	STARTING	Project today		
11	7925		Neg Air - Project 2							
12	7926		Field Blank	FB						
13	7927		Field Blank	FO						

Sample Type: B = Background PA = Pre-Abatement E = Environmental WA = Work Area F = Final BL = Blank P = Personal EL = Excursion Limit

Chain of Custody	Print Name	Sign Name	Date	Time
Sampled By:	Scott Landry	<i>[Signature]</i>	5-22-09	
Relinquished By:	Scott Landry	<i>[Signature]</i>	5-22-09	
Received at Lab By:	Carline Rendell	<i>[Signature]</i>	5-22-09	
Turnaround Time:	RUSH (Specify):		24 Hour	48 Hour
Please contact the following individual(s) at the following number(s) with results:				

By signing above, I acknowledge that the data recorded on this form was collected by accurately following air-sampling procedures outlined in NYS/DOL Industrial Code Rule 56 (12 NYCRR Part 56, Subpart 56-4, 56-6, 56-7.1, 56-8.1, 56-9.1, 56-10.1) and all other applicable state and federal regulations.