



Asbestos Air Sampling Analysis Report

Analyzed in accordance with
NIOSH Method 7400 (A Rules)
NYS DOH ELAP #11555

Client: SUNY College at Potsdam - 44 Pierre Pont Ave., Potsdam, NY 13676

Project Location: Timerman - Basement - Project #2 - Floor Tile/Mastic

Project Number: EL09A-7

Client Contact: Andy Martin

Phone Number: (315) 267-2135

Contractor: Op-Tech

Report Number: 1271

Date Sampled: 5-26-09

Date Received: 5-28-09

Date Analyzed: 5-28-09

Date Reported: 5-28-09

Summary: On May 26, 2008, our representative, Scott Landry, collected the following samples in accordance with all state and federal regulations.

Work Area Location	Sample Type	Elapsed Time Minutes	Flow Rate L/Min	Volume liters	Result f/mm ²	Result f/cc	Field ID	Lab ID
Ambient	E	540	1.5	810	<6.87	<0.003	1	8198
Critical Barrier #1	E	500	1.5	750	8.11	0.004	2	8199
Critical Barrier #2	E	500	1.5	750	<6.87	<0.004	3	8200
Personal Decon	E	515	1.5	772.5	14.98	0.008	4	8201
Waste Out	E	512	1.5	768	<6.87	<0.003	5	8202
Negative Air	E	550	1.5	825	<6.87	<0.003	6	8203
Field Blank	FB	NA	NA	NA	NC	NC	7	8204
Field Blank	FB	NA	NA	NA	NC	NC	8	8205

High or unusual results are highlighted and italicized.

ABBREVIATIONS:

B = Background Sample

PA = Pre - Abatement Sample

E = Daily Environmental Sample

F = Final Clearance Sample

WA = Work Area Sample

STEL/EL = Short Term Exposure/Excursion Limit Sample

P = OSHA Personal Air Monitoring Sample

FB = Field Blank

NC = Non-Contaminated

MD = Mineral Dust, Unable to Analyze

SD = Sample Damaged, Unable to Analyze

f/cc = Fibers Per Cubic Centimeter

f/mm² = Fibers Per Square Millimeter

< = Below Detection Limit

NS = Not Supplied

NA = Not Applicable

Valerie Lare

Approved By: Valerie Lare

Technical Director - Envirologic of New York, Inc.

Disclaimer: NIOSH Method 7400 is a method used for estimating asbestos concentrations, however, phase contrast microscopy cannot distinguish between asbestos fibers and other fiber types. The analytical results presented in this report and the laboratory procedures used are considered to be accurate and reliable for the samples analyzed. This report may not be reproduced without the approval of Envirologic New York, Inc., and then only in full. Envirologic of New York's liability is limited to the cost of the analysis.

Envirologic of New York, Inc.

Central Office: 6950 East Genesee Street, Fayetteville, New York 13066

Ph: (315) 455-2714 Fax: (315) 455-3022



PROJECT #: EL09A-7

LAB REPORT #: ~~0198~~ 1270

[illegible]

Chain of Custody	Print Name	Sign Name	Date	Time
Sampled By:	Scott Landry		5-26-09	
Relinquished By:	Scott Landry		5-26-09	
Received at Lab By:	KATE CONGOLON		5-28-09	1055
Turnaround Time:	RUSH (Specify):		24 Hour	48 Hour
Please contact the following individual(s) at the following number(s) with results:				

➤ Please contact the following individual(s) at the following number(s) with results:

By signing above, I acknowledge that the data recorded on this form was collected by accurately following air-sampling procedures outlined in NYSDOL Industrial Code Rule 56 (12 NYCRR Part 56, Subpart 56-4, 56-6, 56-7.1, 56-8.1, 56-9.1, 56-10.1) and all other applicable state and federal regulations.