



Tim 052709 - ENV - AIR MON
Asbestos Air Sampling Analysis Report

Analyzed in accordance with
 NIOSH Method 7400 (A Rules)
 NYS DOH ELAP #11555

Client: SUNY College at Potsdam - 44 Pierre Pont Ave., Potsdam, NY 13676

Project Location: Timmerman Hall - Basement - Project #2 - Floor Tile/Mastic

Project Number: EL09A-7

Client Contact: Andy Martin

Phone Number: (315) 267-2135

Contractor: Op-Tech

Report Number: 1270

Date Sampled: 5-27-09

Date Received: 5-28-09

Date Analyzed: 5-28-09

Date Reported: 5-28-09

Summary: On May 27, 2008, our representative, Scott Landry, collected the following samples in accordance with all state and federal regulations.

Work Area Location	Sample Type	Elapsed Time Minutes	Flow Rate L/Min	Volume liters	Result f/mm ²	Result f/cc	Field ID	Lab ID
Inside Work Area - East	F	90	10.0	900	<6.87	<0.003	1	8186
Inside Work Area - West	F	90	10.0	900	<6.87	<0.003	2	8187
Inside Work Area - Center	F	90	10.0	900	<6.87	<0.003	3	8188
Inside Work Area - North	F	90	10.0	900	<6.87	<0.003	4	8189
Inside Work Area - South	F	90	10.0	900	<6.87	<0.003	5	8190
Outside Work Area - Outside Decon	F	90	10.0	900	9.36	0.004	6	8191
Outside Work Area - Outside Decon	F	90	10.0	900	14.36	0.006	7	8192
Outside Work Area - Outside Decon	F	90	10.0	900	12.48	0.005	8	8193
Outside Work Area - Outside Decon	F	90	10.0	900	<6.87	<0.003	9	8194
Outside Work Area - Outside Decon	F	90	10.0	900	<6.87	<0.003	10	8195
Field Blank	FB	NA	NA	NA	NC	NC	11	8196
Field Blank	FB	NA	NA	NA	NC	NC	12	8197

Results are satisfactory in accordance with Industrial Code Rule 56-4.11.

High or unusual results are highlighted and italicized.

ABBREVIATIONS:

B = Background Sample

PA = Pre - Abatement Sample

E = Daily Environmental Sample

F = Final Clearance Sample

WA = Work Area Sample

STEL/EL = Short Term Exposure/Excursion Limit Sample

P = OSHA Personal Air Monitoring Sample

FB = Field Blank

NC = Non-Contaminated

MD = Mineral Dust, Unable to Analyze

SD = Sample Damaged, Unable to Analyze

f/cc = Fibers Per Cubic Centimeter

f/mm² = Fibers Per Square Millimeter

< = Below Detection Limit

NS = Not Supplied

NA = Not Applicable

Valerie Lare

Approved By: Valerie Lare

Technical Director - Envirologic of New York, Inc.

Disclaimer: NIOSH Method 7400 is a method used for estimating asbestos concentrations, however, phase contrast microscopy cannot distinguish between asbestos fibers and other fiber types. The analytical results presented in this report and the laboratory procedures used are considered to be accurate and reliable for the samples analyzed. This report may not be reproduced without the approval of Envirologic New York, Inc., and then only in full. Envirologic of New York's liability is limited to the cost of the analysis.

Envirologic of New York, Inc.

Central Office: 6950 East Genesee Street, Fayetteville, New York 13066

Ph: (315) 455-2714 Fax: (315) 455-3022



Air Sample Log / Chain of Custody

6950 E. Genesee St. • Fayetteville, New York 13066 • Telephone (315) 455-2714 • Fax (315) 455-3022

PROJECT #: EL09A-7

LAB REPORT #: 1270

Project Name/City/Project Info: <u>FOOTBALL</u>		Client Name: <u>Sony Polsdam</u>	Client phone #:
<u>Timmerman Hall Basement Project</u>		Client Address: <u>44 Pierrepont Ave. Polsdam, NY 13876</u>	Client fax #:
Date: <u>5-27-09</u>	Contractor: <u>DQ-Tech</u>	Hygienist:	Rotometer #: <u>EL4</u>
		Contact: <u>Andy Markin</u>	Calibration: <u>4-14-09</u>

Sample Number	Lab ID	Work Area ID	Sample Location	Sample Type	Pump #	Start Time	Stop Time	Total Minutes	Calibration		Volume (Liters)
									l/m	l/in	
1	2186		EAST	F		12:05	13:35	90	10	10	900
2	2187		WEST			12:06	13:36		10	10	
3	2188		Center			12:07	13:37		10	10	
4	2189		NORTH			12:08	13:38		10	10	
5	2190		SOUTH			12:09	13:39		10	10	
6	2191		D.J.A		078	11:10	12:40		10	10	
7	2192		All pumps are		630	11:11	12:41		10	10	
8	2193		outside clean in front		3	11:12	12:42		10	10	
9	2194		of staircases		024	11:13	12:43		10	10	
10	2195				22	11:14	12:44		10	10	
11	2196		Field Blank	FB							
12	2197		Field Blank	FB							

Sample Type: B = Background PA = Pre-Abatement E = Environmental WA = Work Area F = Final BL = Blank P = Personal EL = Excursion Limit

Chain of Custody	Print Name	Signature	Date	Time
Sampled By:	Scott Landry		5-27-09	
Relinquished By:	Scott Landry		5-27-09	
Received at Lab By:	KATIE CONGDON		5-28-09	1015
Turnaround Time:	RUSH (Specify):		24 Hour	48 Hour
Please contact the following individual(s) at the following number(s) with results:				

By signing above, I acknowledge that the data recorded on this form was collected by accurately following air-sampling procedures outlined in NYS DOL Industrial Code Rule 56 (12 NYCRR Part 56, Subpart 56-4, 56-6, 56-7.1, 56-8.1, 56-9.1, 56-10.1) and all other applicable state and federal regulations.